Department of Purchasing & Contract Compliance



September 4, 2015

Re: #15ITB98691K-JAJ- Justice Center Tower Roof Replacement

Dear Bidders:

Attached is one (1) copy of Addendum 3, hereby made a part of the above referenced #15ITB98691K-JAJ- Justice Center Tower Roof Replacement..

Except as provided herein, all terms and conditions in the #15RFP98691K-JAJ – Justice Center Tower Roof Replacement referenced above remain unchanged and in full force and effect.

Sincerely, *James A. Jones*James A. Jones

Assistant Purchasing Agent



#15ITB98691K-JAJ – Justice Center Tower Roof Replacement Addendum No. 3 Page Two

This Addendum forms a part of the contract documents and **modifies** the original RFP documents as noted below:

 Question: Please clarify that since this scope only involves the LP system on the roof, a UL inspection and UL Letter of Findings (which will certify the installation of the roof system) is all that is required after completion of the install. In the lightning protection spec (Section 26 41 13 - 3.4), a Master Label is mentioned which would require an inspection and update of the LP system in the entire facility. Please confirm.

Answer: The County's Consultant would only recommend that a UL Master Label Certification be required for the Lightning Protection System in the event that the existing system or any of the components (existing grounding,roof conductors, down conductors, through-roof connectors and/or air terminals) were damaged during the construction process.

ACKNOWLEDGEMENT OF ADDENDUM NO. 2

The undersigned proposer acknowledges receipt of this addendum by returning one (1) copy of this form with the bid package to the Department of Purchasing, Fulton County Public Safety Building, 130 Peachtree Street, Suite 1168, Atlanta, Georgia 30303 by the Bid due date and time **Wednesday, September 16, 2015, 11:00 A.M.**

This is to acknowledge receipt of Addendum No. 1, 2015.	day of
Legal Name of Bidder	
Signature of Authorized Representative	
Title	